

To: Daly, Eric[Daly.Eric@epa.gov]
From: Lisichenko, Peter
Sent: Fri 5/13/2016 12:49:19 PM
Subject: RE: HTC-5374 Roberts Street

Working on it. Was having connection problems at the hotel this morning. I'm trying to work on this between subway stops.

-Pete

Peter Lisichenko

Cell/text: (603) 512-4350

From: Daly, Eric [mailto:Daly.Eric@epa.gov]
Sent: Friday, May 13, 2016 8:44 AM
To: Lisichenko, Peter
Subject: FW: HTC-5374 Roberts Street

FYI. The figure with the floor plan dimensions is all we need to complete questions from the radon installer.

From: Daly, Eric
Sent: Friday, May 13, 2016 8:20 AM
To: Kevin Shaver (kshaver@gesoncall.com) <kshaver@gesoncall.com>;
djohnson@gesoncall.com; Richard Cole (rcole@gesoncall.com) <rcole@gesoncall.com>
Subject: HTC-5374 Roberts Street

Good Morning:

Below are the answers to the radon system installer. I have attached a

basic footprint map of the basement. However, Peter will be providing us a map with measurements shortly.

- Basement is all concrete
- Sump is concrete with drain tile in floor draining to sump area
- Basement has been dry
- There is no gaps between basement flooring and upright walls
- There are a few settlement cracks that exists in floor and walls
- No Radiant heat in flooring in basement
- The new addition/family room is built on a surrounding footer on 2x12 floor joists

Regards,

Eric

"We must, indeed, all hang together, or assuredly we shall all hang separately", Benjamin Franklin

Eric M. Daly

On-Scene Coordinator/Radiological Response Specialist
US Environmental Protection Agency- Region II

ERRD/RPB/PPS
2890 Woodbridge Avenue
Edison, NJ 08837
daly.eric@epa.gov
732-321-4350

CONFIDENTIALITY: This email and attachments may contain information which is confidential and proprietary. Disclosure or use of any such confidential or proprietary information without the written permission of Weston Solutions, Inc. is strictly prohibited. If you received this email in error, please notify the sender by return e-mail and delete this email from your system. Thank you.